

Main Entry/ Club Lighting
1" = 30'



Notes

1. This is a drawing based on an overlay tracing of an aerial photograph.
2. All lighting locations to be located and approved by MSA Design.

Add Vicinity, Prepare for DRG	2.1.2010
Client	11.2.2009
Field Conditions	10.14.2009
Finals with New Bollard	10.7.2009
Revise and send to Lighting rep	6.11.2009
Revise Specs	6.7.2009
To Contractor	5.15.2009
Conceptual Review	2.1.2009

MSA Design


Land Planning Site Planning Urban Design
American Society of Landscape Architects
461 Carter Road Naples, FL 34108 239.598.2828 inquiry@msadesign.com

Spring Run at The Brooks
9501 Spring Run Boulevard
Bonita Springs, FL 34135


Main Entry and Clubhouse Lighting Plan

Key	Qty	Description	Area	Manufacturer	Fixture/ Arm	Pole
◇	1	Single Head	Main Entry	Whatley	Mounting Arm: PT01; Fixture Whatley 1390, 70MH, Medium base socket, 120V, Lamp Included	ST45 10' above grade, Dark Green, Direct Embedded; Base- D17M with Quad outlet GFCI each
◇	1	Single Head	Main Entry	Whatley	Same	Same
◇	1	Single Head	Main Entry	Whatley	Same	Same
◇	1	Single Head	Main Entry	Whatley	Same	Same
◇	1	Bollard	Main Entry	Visionaire	Sahara SAH-B	Forest Green
◇	1	Double Head	Club Entry	Whatley	Mounting Arm: PT01; Fixture Whatley 1390, 70MH, Medium base socket, 120V, Lamp Included	Same
◇	1	Single Head	Club Parking	Whatley	Same	Same
◇	1	Single Head	Club Parking	Whatley	Same	Same
◇	1	Single Head	Club Bag Drop	Whatley	Same	Same

Lighting Rep:
Steve Vacchiano
Envision
1500 Colonial Blvd, Suite 100
Ft. Myers, FL
Cell: 239.872.6007
Office: 239.303.5136



Whatley 1390



Whatley ST45 w/ D17M